

# AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
---------------------	------	----	-------

2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
-------------------------------	-------------------	----------------------------------	--------------------------------

6. ISSUED BY <span style="float: right;">CODE</span>	7. ADMINISTERED BY (If other than Item 6) <span style="float: right;">CODE</span>
---	--

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO.
		9B. DATED (SEE ITEM 11)
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

### 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

### 13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR  <span style="float: right;">(Signature of person authorized to sign)</span>	15C. DATE SIGNED
16B. UNITED STATES OF AMERICA  <span style="float: right;">(Signature of Contracting Officer)</span>	16C. DATE SIGNED

Amendment 0003 is hereby incorporated into solicitation SP3100-08-B-5010 and shall become part of any contract.

Amendment 0003 is being issued to provide answers to vendor questions and extend the bid opening date.

Question 1: The bid documents provide only 45 days for completion. The canopy suppliers are asking for 4 to 6 weeks to fabricate and deliver the canopies once the shop drawings are approved. Will more time be allowed?

Answer 1: Refer to Section F, Paragraph F-3, Clause 52.211-10, Commencement, prosecution and completion of work. The completion time period for the contract is hereby changed from 45 days to 75 days.

Question 2: Refer to Amendment 0002 dated September 12, 2008. The answer to question 2 for the use of rigid conduit states that flex wiring may not be used. The canopy manufacturer uses RELOC wiring for all their installations for lighting and switches as a standard installation. Do we need to have the manufacturer delete this wiring out of his price and install rigid for the entire lighting install?

Answer 2: Yes, The requirement for galvanized rigid conduit remains for this application.

The bid opening date and time for this solicitation is hereby extended from September 18, 2008 to September 19, 2008 2:00 PM, Building 404.

All other terms and conditions remain unchanged.

**END OF AMENDMENT 0003**